



Application for Food Service Establishment Permit

Original \$400
 Renewal \$400
 Temporary \$50

Please Print or Type Permit# _____

Establishment Name (as on sign): _____

Corporate/LLC Name: _____

Establishment Location: _____

Mailing Address (if different than above): _____

Phone No: _____ Email: _____

Manager/Person in Charge: _____ Phone: _____

Corporate Contact: _____ Phone: _____

Corporate Address: _____

Corporate Email: _____

Please check this box if you want a copy of the permit mailed to a different address and provide address below:

Property Owner's Name: _____ Phone: _____

Property Owner's Address: _____

Property Owner's Email: _____

Certified Food Manager's Certification: Email Address:	License #	Expiration:
Certified Food Manager's Certification: Email Address:	License #	Expiration:

Applicant's Printed Name

Applicant's Signature Date

All Food Establishments are required to have a Certified Food Manager on duty at all times.

All Permits expire December 31st.



MOBILE FOOD VEHICLES

All mobile food vehicles will be inspected.

Below is a list of items the Fire Marshal will be checking.

1. **Smoking** shall not be permitted in mobile food vehicles. Approved "No Smoking" signs shall be conspicuously posted.
2. **Portable Fire Extinguishers** shall be provided. A minimum 2-A;10-BC multi-purpose fire extinguisher shall be currently inspected and tagged by a Licensed Technician.
 - If producing grease-laden vapors, one additional fire extinguisher must be a Type K extinguisher.
3. **Type 1 Hood** shall be installed at or above all cooking appliances that produce grease-laden vapors. Type 1 hood systems shall be installed with an approved and inspected Fire Suppression System. A Type K Fire Extinguisher is also a requirement in the installation of a Fire Suppression System.
4. **Appliances** shall be secured in place and connected to fuel-supply-piping complying with ANSI Z21.69/CSA 6.16. The connections shall be inspected on a regular basis and at least once a year by a licensed plumber.
5. **Cooking Oil Storage** shall not exceed 120 gallons total and shall be stored in such a way as to not be toppled or damaged during transport.
6. **Generators and other internal combustion power sources** shall be secured and the exhaust shall terminate at a location that does not allow entry into the enclosed area.
7. **LP-gas or CNG** containers shall be securely mounted and restrained to prevent movement.
 - Piping shall be installed to the appropriate NFPA guidelines.
 - System piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage and damage from vibration.
 - The connections shall be inspected on a regular basis and at least once a year by a licensed plumber.
8. **All Life Safety Systems** shall be inspected annually and maintained as required by the specific trade.